

COUNTY OF SANTA BARBARA ♦ CERTIFIED UNIFIED PROGRAM AGENCY

225 Camino del Remedio, Santa Barbara CA 93110 ♦ (805) 681-4900 ♦ Fax (805) 681-4901
2125 S. Centerpointe Parkway, Rm. 333, Santa Maria, CA 93455 ♦ (805) 346-8460 ♦ Fax (805) 346-8485

APPLICATION TO REMOVE AN UNDERGROUND HAZARDOUS SUBSTANCE STORAGE TANK

Santa Barbara County CUPA Form 307

FOR OFFICE USE	
Operating Permit #	
Date Received:	
# of Tanks	
Fee Paid	SEE FEE SCHEDULE
Receipt #	

Applicant must submit this completed application with supporting documentation, signed UST Removal Requirements, and applicable fees. Information for the tanks submitted to CERS that has been 'accepted' may be submitted in lieu of section D below.

A. FACILITY / SITE INFORMATION: CERS ID (if applicable): _____

Site Name: _____

Site Address: _____

B. TANK OWNER/OPERATOR:

Name: _____

Mailing: _____ Email: _____

Contact: _____ Telephone: _____

24 Hour Emergency Contact: _____ Telephone: _____

C. CONTRACTOR: Contractors acting as an agent for the tank owner must also submit a letter from the tank owner authorizing their agent status (Authorized Agent Letter).

Primary Contractor: _____

Mailing: _____ Email: _____

Name of Contact on Site: _____ Telephone: _____

License #: _____ Type of License: _____

Worker's Compensation Insurance Company: _____

Insurance Company Telephone: _____

Proposed Start Date: _____

All Sub Contractors: _____ License #: _____

_____ License #: _____

NOTE: You are responsible for contacting the following agencies prior to tank removals:

Local Fire Department, Air Pollution Control District, Building Department and Cal OSHA

D. TANK HISTORY: Utilize additional pages for sites with greater than four tanks being removed, or submit UST(s) information from CERS.

TANK HISTORY	TANK ID #:	TANK ID #:	TANK ID #:	Tank ID#:
ID # AND SIZE OF TANK				
DATE AND TYPE OF ANY REPAIRS				
DATES AND TYPES OF ANY MODIFICATIONS				
SUBSTANCES STORED IN TANK				

CERS INFORMATION MAY BE PRINTED/SUBMITTED. FOR AbUSTs FILL OUT TABLE ABOVE

E. TANK REMOVAL: Describe your tank removal plan. Plan must be in compliance with applicable requirements of HSC Code, Chapter 6.7, Section 25298 and CCR Title 23, Section 2672. You must indicate whether or not you plan to cut on/into the UST

F. HAZARDOUS WASTE AND SAMPLING INFORMATION:

Rinsate Hauler's Name: _____

Rinsate Hauler's Address: _____

Tank Rinsate Disposal/Recycling Facility's Name: _____

Tank Rinsate Disposal/Recycling Facility's Address: _____

Tank Disposal Facility / Address _____

Samples Taken By: _____

Analytical Laboratory's Name: _____ Certification #: _____

Analytical Laboratory's Address: _____

Degasser Name: _____

Degasser's Address: _____

NOTE: Liquid, sludge or semi-solid material found inside a UST shall be treated as Hazardous Waste unless representative samples are taken and the following analytics are applied to the samples: TCLP for VOCs, TCLP (STLC as needed) for Title 22 Metals, pH, closed cup flashpoint test, and fish bioassay test. If all samples pass all tests then the material may be considered non-hazardous waste. Failure to properly sample or have sampling witnessed by a CUPA inspector will nullify test results and will require re-sampling or have the material be treated as Hazardous Waste.

G. SUBMIT A SAMPLING PLAN THAT SHOWS WHERE SOIL SAMPLES WILL BE TAKEN RELATIVE TO THE TANK(S), PIPING RUNS, AND DISPENSERS

H. SUBMIT A SITE SPECIFIC HEALTH AND SAFETY PLAN - PLAN MAY BE REQUIRED TO BE CERTIFIED BY AN INDUSTRIAL HYGIENIST

I. SUBMIT A PLOT PLAN WITH THIS APPLICATION. PLOT PLAN SUBMITTED TO CERS MAY BE SUBMITTED PROVIDED IT HAS BEEN 'ACCEPTED.'

J. DEPTH OF FIRST GROUNDWATER: _____

HOW DETERMINED: _____

REMEMBER TO UPDATE THE FACILITY'S BUSINESS ACTIVITIES INFORMATION AND INVENTORY ON CERS WITHIN 30 DAYS AFTER TANKS ARE REMOVED AS APPLICABLE. TANKS MUST BE CLOSED VIA A NEW SUBMITTAL IN CERS WITHIN 30 DAYS OF REMOVAL.

I declare to the best of my knowledge and belief, the statements and information provided are true and correct.
I understand that additional information may be needed in order to obtain approval from the CUPA.
I have read and understand the UST Removal Requirements and have provided a signed copy with this application.

I will notify the CUPA at least **one week before** tank removal is to begin, in order to schedule the first required inspection.
I will authorize the laboratory to release analytical results directly to the County Hazardous Materials Unit as soon as they are available.

Signature: _____ Title: _____

Print Name: _____ Date: _____

Telephone Number: _____

APPROVED APPLICATIONS ARE VALID FOR 90 DAYS FROM DATE OF ISSUANCE.

FOR OFFICE USE ONLY:

In approving this permit application, the CUPA has reviewed the application for compliance with Chapter 16 of Division 3 of Title 23 of the California Code of Regulations (CCR), Division 4.5 of Title 22 CCR, and Chapters 6.5 and 6.7 of Division 4.5 of the California Health & Safety Code. No review of compliance was conducted of, nor shall this approval be construed as extending to, the provisions of any other rule, regulation or standard including but not limited to: the California Building Code, California Electrical Code, and the California Fire Code.

Approved / Denied By: _____ Date: _____

CUPA conditions of approval: based on forms and plans as submitted -- any changes must be reflected on new forms and plans, and approved:

1. Adhere to the permitting requirements of other County agencies, e.g. Building Department, Local Fire Department.
2. Ensure the applicable local Fire Department has been notified of tank removal activity; obtain approvals as required.
3. Comply with all applicable OSHA regulations.
4. Segregate all contaminated soil encountered; place on visqueen and cover. Failure to segregate shall result in escalated soil sampling requirements for stockpiled soil.
5. Expose all piping associated with the tanks and assure piping is also rinsed.
6. Utilize, at a minimum, 3% of tank volumes for rinsing tanks.
7. Submit a copy of the lab report, chain of custody documentation and uniform hazardous waste manifest for rinsate disposal and contaminated soil disposal within 30 days of removal (Closure Report).
8. Observe the 90 day storage limit for hazardous waste, e.g. contaminated, stockpiled soil. Proper storage requirements for a hazardous waste also apply.
9. Secure open excavations per Building Department requirements, if applicable.
10. If additional conditions apply; they will be itemized on a separate document included with the returned plan check application.